



R-average 39,6 dB
 Sum deviation 30,0 dB
Rw 42 dB
 Dividing wall area 11,4 m²
 Room volume 55,0 m³

| | |
|--------|---------|
| 100 k | 15,0 dB |
| 125 k | 18,7 dB |
| 160 k | 22,8 dB |
| 200 k | 28,5 dB |
| 250 k | 39,4 dB |
| 315 k | 39,7 dB |
| 400 k | 39,9 dB |
| 500 k | 40,7 dB |
| 630 k | 41,8 dB |
| 800 k | 43,7 dB |
| 1 k | 44,7 dB |
| 1,25 k | 43,5 dB |
| 1,6 k | 47,4 dB |
| 2 k | 52,2 dB |
| 2,5 k | 56,5 dB |
| 3,15 k | 57,9 dB |

Test method in accordance with ISO 140/3