



| | | | |
|--------------------|---------------------|--------|---------|
| R-average | 44,7 dB | 50 k | 17,1 dB |
| Sum deviation | 27,0 dB | 63 k | 15,1 dB |
| Rw | 49 dB | 80 k | 20,3 dB |
| Dividing wall area | 11,4 m ² | 100 k | 24,6 dB |
| Room volume | 55,0 m ³ | 125 k | 30,9 dB |
| | | 160 k | 34,7 dB |
| | | 200 k | 38,7 dB |
| | | 250 k | 39,8 dB |
| | | 315 k | 41,0 dB |
| | | 400 k | 46,3 dB |
| | | 500 k | 47,4 dB |
| | | 630 k | 47,0 dB |
| | | 800 k | 47,1 dB |
| | | 1 k | 49,6 dB |
| | | 1,25 k | 53,0 dB |
| | | 1,6 k | 60,6 dB |
| | | 2 k | 62,5 dB |
| | | 2,5 k | 62,5 dB |
| | | 3,15 k | 65,2 dB |
| | | 4 k | 66,0 dB |
| | | 5 k | 69,3 dB |

Test method in accordance to ISO 140/3