



R-average	38,2	dB	50 k	20,3	dB
Sum deviation	28,7	dB	63 k	14,3	dB
Rw	42	dB	80 k	17,3	dB
Dividing wall area	11,0	m ²	100 k	15,1	dB
Room volume	55,0	m ³	125 k	15,7	dB
Test method in accordance to ISO 140-3:95			160 k	21,8	dB
			200 k	32,8	dB
			250 k	34,7	dB
			315 k	37,9	dB
			400 k	39,6	dB
			500 k	42,9	dB
			630 k	42,6	dB
			800 k	42,9	dB
			1 k	45,7	dB
			1,25 k	47,0	dB
			1,6 k	48,5	dB
			2 k	48,4	dB
			2,5 k	47,4	dB
			3,15 k	47,9	dB
			4 k	51,3	dB
			5 k	55,9	dB